

2006 User Conference
& Technology Fair

Requirements in Nuclear Applications – Digital Videograph Recorders



Randy Long

**Senior Design Engineer
I&C**

30 NOV 2006


PRESENTATION AGENDA

- Bruce Power
- The Project
- Software Quality Assurance
- Human Factors
- Stakeholder Participation
- Configuration and Archiving
- Q&A




About Bruce Power

- Largest nuclear site in North America
- Spread over 2,300 acres and has 56 kms of roadways
- Includes supporting infrastructure, training centre, Visitors' Centre
- About 3,700 employees



BRUCE POWER SITE

Yokogawa Technology
Innovations Fair &
User Conference



Another
1,500 MW
to be added
with restart
of Units 1
and 2

Presently 6
Operating
Units.
Capacity of
4,700 MW


THE PROJECT

- Seventeen (17) Chart Recorders on MCR Panels per Unit
- Business Case Built on Obsolescence
- Priority on Operations Need / Perceived Risk
- Objectives:
 - » Form / Fit / Function
 - » Training
 - » Modification Impact



MAIN CONTROL ROOM PANELS

Yokogawa Technology
Innovations Fair &
User Conference



- Bruce Power have specific set of Sector Guidelines and Requirements for SQA
- OASES SQA Standard = Ontario Hydro AECL Software Engineering Standards
 - Suite of software standards which covers:
 - Categorization
 - Graded Software Engineering Standards
 - Guideline for Qualification of Software Products
 - Guideline for Assessment of Configurable Software
 - Modification of Existing Software

- Categorization
 - OASES Guideline for Categorization
 - Dependant on Nuclear Safety Criticality and Risk of Target Application
 - Also defined as Plant Safety Significance versus Software Failure Impact
- Graded Categories:
 - CAT I Highest Safety Significance
 - CAT II Moderate Safety Significance
 - CAT III Lowest Safety Significance

- Standards for Software Engineering
- Each Category I, II or III has specific standards for the development of software.
- Standards were developed in early 1990s in response to Regulator's Action Item.
- Standards developed with focus on Custom Software written for Specific Applications.
- OASES standards are only followed by select manufacturers with primary interest in CANDU Reactors.

- **Guide for Qualification of Software Products**
- Recognizes products are not developed to OASES Standards.
- Attempts to Qualify software development processes by other manufactures for defined Safety Category.
- Uses Qualification Methods to Audit Manufacturers SQA Capabilities.
- Assessment tools are Checklists, Questionnaires, Site visits, Interviews.

- **Guideline for Assessment of Configurable Software**
- The development of software is not our core business.
- Bruce Power relies on Vendors / Manufacturers to configure devices for specific applications.
- Guideline is used to ensure proper Engineering i.e. Requirements, Design, Implementation, are followed in the development of the configurable Software.
- Credit is given for Industry accepted Standards such as IEC 61131.

THIRD PARTY QUALIFICATION

- In Lieu of performing SQA Audit a Third Party Qualifications can be accepted.
- Credit taken for previous qualifications or certifications.
- Designer is still responsible for ensuring Application Independent Software related Qualification Concerns are addressed.
- Typical equivalent programs:
 - IEC 61508 SIL 1, 2, 3
 - IEC 61513 SIL 1, 2, 3
 - IEEE 7-4.3.2
 - CFRR 50 APP B – 1E
 - ISO/IEC 12207

- H.F Evaluation
 - Human Factors is addressed for all Modifications.
 - Questionnaire / Checklist will define Human Factors as Minor or Major.
 - MAJOR = Human Factors Evaluation (HFE).
 - HFE consists of 12 Elements which must be addressed or dispositioned in a HF Report.
 - Focus is:
 - OPEX
 - TASK ANALYSIS
 - STAFFING
 - DESIGN

- Human Factors... The Project
- Chart Recorder replacement was initially defined as Minor Change however HF Evaluation was completed based on “first time” change of MCR Panels.
- From HF perspective, change to Digital Videograph recorders considered Minimal Impact to Operators.
- Added tasks to display data considered minimal risk for Operator Error.
- Training requirements satisfied by Vendor demonstration and good Operating Manual.

HUMAN FACTORS - COMPARISON

SAME

Vertical Trend

Scales on Top



IMPROVED

Engineering Units

Time & Date




HUMAN FACTORS - IMPROVEMENTS

Yokogawa Technology
Innovations Fair &
User Conference



HUMAN FACTORS - INFORMATION

Yokogawa Technology
Innovations Fair &
User Conference



LOCK

TAG ID

PV

ENG UNITS

NAVIGATION

FAVORITES

STATUS LED

TIME DATE
TREND
INTERVAL


HUMAN FACTORS

Yokogawa Technology
Innovations Fair &
User Conference



HUMAN FACTORS

Yokogawa Technology
Innovations Fair &
User Conference



STAKEHOLDER PARTICIPATION

Yokogawa Technology
Innovations Fair &
User Conference



- **Early Promotion of Product**
- Vendor (C.B Engineering) on site after original contact with Bruce Power. Presentation to Design Department.
- As project went through funding Vendor assisted in Technical Specification details.
- Vendor and Yokogawa Rep on site with Operators for display of product.
- Yokogawa Rep assisted with Nuclear Standards such as Software Qualification Issues.
- Similar co-operation provided to other technical group i.e. Simulator, Restart Team.

CONFIGURATION

- User Friendly
- Users Manual and Operations Manual provided early in project for review of Maintenance, Operations and Engineering.
- Vendor to site prior to installation to assist Maintenance with configuration.
- After installation, Vendor to site for commissioning activities. Changes per Operations upon initial installation...through commissioning.
- Vendor back to site after 4 months of Operations Use for final configuration...existing.

- Continued
- Taking existing configuration for Unit 4 devices and downloading into Unit 3 devices. Only change is TAG NAMES.
- Simulator configuration = download of presently installed devices
- Configuration Data Dump = Instruments Calibration History

- DATA Query
- Data Retention by internal 80Mb memory and 32Mb compact flash media.
- Low priority to archive data as information is sent in parallel to Plant Information System, OSI PI.
- Have decided to make backups manual if information needs to be retrieved and taken externally.
- Option being presented to have the 17 devices per unit be networked together and download data to local server.
- Future consideration. Not a requirement due to present use of OSI PI.

QUESTIONS & ANSWERS

Yokogawa Technology
Innovations Fair &
User Conference



INNOVATED BY
YOKOGAWA
POWERED BY
CUSTOMERS

Q & A

