



Manual No : IM 34M6H28-01E  
Manual Name : DeviceNet Scanner Module  
Edition : 1st Edition

### ■ Page 5-4

Add the following caution text.

#### ● Grounding of communication cables

To ensure compliance to CE Marking for a system incorporating this module, use a shielded cable for connecting to the module. Peel off part of the insulation of the shielded cable to expose the shield, and apply an FG clamp to the shield to secure and ground it.

