



Member of the FM Global Group

FM Approvals  
1151 Boston-Providence Turnpike  
P.O. Box 9102 Norwood, MA 02062 USA  
T: 781 762 4300 F: 781 762 9375 www.fmapprovals.com

# CERTIFICATE OF COMPLIANCE

## HAZARDOUS (CLASSIFIED) LOCATION ELECTRICAL EQUIPMENT

This certificate is issued for the following equipment:

### **MW100 Series Data Acquisition Unit.**

#### **MW100-a-bc/d Main Module.**

**NI / I / 2 / ABCD / T4 Ta = 60°C – NFM015-A13; NIFW.**

a = Instruction Manual Language J or E.

b = Power Supply Voltage 3

c = Power Inlet & Power Cord, W

d = Option Function C2, C3, M1, S7, and/or S8\*

\* C2 and C3 cannot be specified together.

Nonincendive Field Wiring Parameters:

Equipment supplying energy	Model	Voc (V)	Isc (mA)	Ca (µF)	La (mH)
	RS232C	8	30	1	1
	RS422A	7	250	1	0.5

Equipment receiving energy	Model	Vmax (V)	I <sub>max</sub> (mA)	Ci (µF)	Li (µH)
	RS232C	30	15	0.001	10
	RS422A	25	0.3	0.001	10

### **MX110-a-b/c Analog Input Module.**

**NI / I / 2 / ABCD / T4 Ta = 60°C – NFM015-A13; NIFW.**

a = Input Type UNV or V4R.

b = Measurement interval & number of channels H04, M06, or M10.

c = Option function NC or S10 \*

\* NC can be specified only for b = M10

Nonincendive Field Wiring Parameters:

Equipment supplying energy	Model	Voc (V)	Isc (mA)	Ca (µF)	La (mH)
	MX110-UNV-H04	5	0.5	1	10
	MX110-UNV-M10	5	0.5	1	10

	MX110-UNV-M10, with 772081	5	0.5	1	10
	MX110-UNV-M10, with 772082	5	0.5	1	10
	MX110-UNV-M10, with 772083	5	0.5	1	10
	MX110-V4R-M06	5	0.5	1	10

Equipment receiving energy	Model	Vmax (V)	I <sub>max</sub> (mA)	C <sub>i</sub> (μF)	L <sub>i</sub> (μH)
	MX110-UNV-H04	30	0.03	0.03	10
	MX110-UNV-M10	30	0.03	0.005	10
	MX110-UNV-M10, with 772081	1.5	100	0.005	10
	MX110-UNV-M10, with 772082	5	30	0.005	10
	MX110-UNV-M10, with 772083	8	20	0.005	10
	MX110-V4R-M06	30	0.03	0.005	10

**MX112-a-b Strain Input Module.**

**NI / I / 2 / ABCD / T4 Ta = 60°C – NFM015-A13; NIFW.**

a = Input Type B12, B35, or NDI.

b = Measurement interval & number of channels M04 or S10.

Nonincendive Field Wiring Parameters:

Equipment supplying energy	Model	Voc (V)	Isc (mA)	Ca (μF)	La (mH)
	MX112-B12-M04	8	20	1	10
	MX112-B35-M04	8	20	1	10
	MX112-NDI-M04	8	20	1	10

Equipment receiving energy	Model	Vmax (V)	I <sub>max</sub> (mA)	C <sub>i</sub> (μF)	L <sub>i</sub> (μH)
	MX112-B12-M04	10	0.01	0.01	10
	MX112-B35-M04	10	0.01	0.01	10
	MX112-NDI-M04	10	0.01	0.01	10

**MX115-a-b/c Digital Input Module.**

**NI / I / 2 / ABCD / T4 Ta = 60°C – NFM015-A13; NIFW.**

a = Input Type D05 or D24.

b = Measurement interval & number of channels H10.

c = Option function NC or S10\*

Nonincendive Field Wiring Parameters:

Equipment supplying energy	Model	Voc (V)	Isc (mA)	Ca (μF)	La (mH)
	MX115-D05-H10	5.6	1.02	5	10
	MX115-D24-H10	8	0.05	5	10

Equipment receiving energy	Model	Vmax (V)	I <sub>max</sub> (mA)	C <sub>i</sub> (μF)	L <sub>i</sub> (μH)
	MX115-D05-H10	10	1	0.005	10
	MX115-D24-H10	50	0.25	0.005	10

**MX120-a-b/c Analog Output Module.**

**NI / I / 2 / ABCD / T4 Ta = 50°C– NFM015-A13; NIFW.**

a = Input Type VAO or PWM.

b = Measurement interval & number of channels M08.

c = Option function S10

Nonincendive Field Wiring Parameters:

Equipment supplying energy	Model	Voc (V)	Isc (mA)	Ca (μF)	La (mH)
	MX120-VAO-M08	22	62.5	0.3	1

**MX125-a-b/c Digital Output Module.**

**NI / I / 2 / ABCD / T4 Ta = 50°C– NFM015-A13; NIFW.**

a = Input Type MKC.

b = Measurement interval & number of channels M10.

c = Option function S10

Nonincendive Field Wiring Parameters:

Equipment receiving energy	Model	Vmax (V)	I <sub>max</sub> (mA)	Ci (μF)	Li (μH)
	MX125-MKC-M10	5	1000	0.005	10
		12	500		
		24	100		

**MX150-a/b Base Plate.**

**NI / I / 2 / ABCD / T4 Ta = 60°C.**

a = Options 1, 2, 3, 4, 5, or 6.

b = Option function S10

**772061 Terminal Block**

**NI / I / 2 / ABCD / T4 Ta = 60°C.**

Note: The 772061 model is applicable only to the MX110-UNV-M10 or MX115-D05-H10 or MX115-D24-H10.

**772062 -a Connection Cable.**

**NI / I / 2 / ABCD / T4 Ta = 60°C.**

a = Cable length, cm,; 050 or 100.

Note: The 772062 model is applicable only between the MX110-UNV-M10 and 772061 or between the MX115-D05-H10 and 772061 or between the MX115-D24-H10 and 772061.

**772063 Plate with Clamp Terminals**

**NI / I / 2 / ABCD / T4 Ta = 60°C.**

Note: The 772063 model is applicable only to the MX110-UNV-M10 or MX115-D05-H10 or MX115-D24-H10.

**772064 Clamp Terminal.**

**NI / I / 2 / ABCD / T4 Ta = 60°C.**

Note: The 772064 model is applicable only to the MX110-UNV-H04.

**772065 Clamp Terminal.**  
**NI / I / 2 / ABCD / T4 Ta = 50°C**

Note: The 772065 model is applicable only to the MX125-MKC-M10 or MX120-VAO-M08 or MX120-PWM-M08.

**772066 Connector Cover for Base Plate.**  
**NI / I / 2 / ABCD / T4 Ta = 60°C.**

**772067 Plate with Clamp Terminals.**  
**NI / I / 2 / ABCD / T4 Ta = 60°C.**

Note: The 772067 model is applicable only to the MX110-V4R-M06.

**772068 Plate with Clamp Terminals (120Ω).**  
**NI / I / 2 / ABCD / T4 Ta = 60°C.**

Note: The 772068 model is applicable only to the MX112-B12-M04 or MX112-B35-M04.

**772069 Plate with Clamp Terminals (350Ω).**  
**NI / I / 2 / ABCD / T4 Ta = 60°C.**

Note: The 772069 model is applicable only to the MX112-B12-M04 or MX112-B35-M04.

**772080 Plate with Screw Terminals.**  
**NI / I / 2 / ABCD / T4 Ta = 60°C.**

Note: The 772080 model is applicable only to the MX110-UNV-M10 or MX115-D05-H10 or MX115-D24-H10.

**772081 Plate with Clamp Terminals.**  
**NI / I / 2 / ABCD / T4 Ta = 60°C.**

Note: The 772081 model is applicable only to the MX110-UNV-M10.

**772082 Plate with Clamp Terminals.**  
**NI / I / 2 / ABCD / T4 Ta = 60°C.**

Note: The 772082 model is applicable only to the MX110-UNV-M10.

**772083 Plate with Clamp Terminals.**  
**NI / I / 2 / ABCD / T4 Ta = 60°C.**

Note: The 772083 model is applicable only to the MX110-UNV-M10.

## Equipment Ratings:

Nonincendive for use in Class I, Division 2, Groups A, B, C, and D, Hazardous (Classified) Indoor Locations; Provides Nonincendive Field Wiring Connections for Class I, Division 2, Groups A, B, C, and D, Hazardous (Classified) Indoor Locations.

## FM Approved for:

Yokogawa Electric Company  
Tokyo, Japan

This certifies that the equipment described has been found to comply with the following Approval Standards and other documents:

Class 3600	1998
Class 3611	2004
Class 3810	2005

Original Project ID: 3029073

Approval Granted: *8 JUNE 2007*

Subsequent Revision Reports / Date Approval Amended

Report Number	Date	Report Number	Date
---------------	------	---------------	------

FM Approvals LLC

  
\_\_\_\_\_  
Roger L. Allard  
Assistant Vice President

*8 JUNE 2007*  
\_\_\_\_\_  
Date