



# Certificate of Compliance

**Certificate:** 1089576 (LR 81741C-74)

**Master Contract:** 172608

**Project:** 2444636

**Date Issued:** August 8, 2011

**Issued to:** Yokogawa Electric Corporation  
2-9-32 Nakacho  
Musashino-shi, Tokyo 180-8750  
Japan  
Attention: Akira Matsunaga

*The products listed below are eligible to bear the CSA Mark shown*



*Jay McVeigh*

**Issued by:** Jay McVeigh

## PRODUCTS

**CLASS 2258 02** - PROCESS CONTROL EQUIPMENT - For Hazardous Locations

Class I, Groups BCD; Class II; Groups EFG; Class III; T6; CSA Encl Type 4X; Class I, Div 2, Groups ABCD -  
Seals not Required:

YTA Series Temperature Transmitter, Model Number YTA110, 310, 320-bAcde/f/g, 42 Vdc max, for use in hazardous locations.

## Notes:

- (1) The above model numbers include suffixes designating transmitter type, output signal, electrical connection, indicator, mounting, and options.
- (2) The suitability of the final installation is to be determined by the local authorities having jurisdiction.

## APPLICABLE REQUIREMENTS

CSA Standards C22.2 No. 0-M1991 - General Requirements — Canadian Electrical Code, Part II.

CSA Standards C22.2 No. 0.4-M1982 - Bonding and Grounding of Electrical Equipment.



**Certificate:** 1089576 (LR 81741C-74)

**Master Contract:** 172608

**Project:** 2444636

**Date Issued:** August 8, 2011

- 
- CSA Standards C22.2 No.25-M1966 - Enclosures for Use in Class II, Group E,F&G Hazardous Locations.  
CSA Standards C22.2 No. 30-M1986 - Explosion Proof Enclosures for use in Class I Hazardous Locations.  
CSA Standards C22.2 No. 94 -M1991 - Special Purpose Enclosures.  
CSA Standards C22.2 No. 142-M1987 - Process Control Equipment.  
CSA Standards C22.2 No. 157-92 - Intrinsically Safe and Non-Incendive Electrical Equipment for use in Hazardous Locations.  
CSA Standards C22.2 No. 213-M1987 - Non-Incendive Electrical Equipment for Use in Class I, Division 2 Hazardous Locations.  
CSA Standards C22.2 No.1010.1-92 - Safety Requirements for Electrical Equipment for Measurement, Control and Laboratory Use Part I: General Requirements.



## *Supplement to Certificate of Compliance*

**Certificate:** 1089576

**Master Contract:** 172608

*The products listed, including the latest revision described below, are eligible to be marked in accordance with the referenced Certificate.*

### **Product Certification History**

---

<b>Project</b>	<b>Date</b>	<b>Description</b>
2444636	August 8, 2011	Update to 1089576 to include Change of temperature range for lower side; correction of manufacture; correction of typographical error; addition of data sheet for epoxy resin

### **History**

LR 81741-c74; October 14, 1998; Original Certification. Certificate of Compliance Issued

1089576; May 30, 2000; Supersedes Report LR 81741-c74 to include alternate construction of YTA to include S.S. Housing and Fieldbus Type